MITSUBISHI

GT12 Backlight for 10.4"/8.4" GOT

User's Manual

GT12-70VLTN
GT12-60VLTN

Thank you for purchasing the GOT1000 Series.

Prior to use, please read both this manual and detailed manual thoroughly to fully understand the product.

MODEL	GT12-70VLTN-U-E
MODEL CODE	1D7MB5
IB(NA)-0800449ENG-A(0910)MEE	

GRAPHIC OPERATION TERMINAL
GOT1000

●SAFETY PRECAUTIONS●

(Always read these precautions before using this equipment.)

Before using this product, please read this manual and the relevant manuals introduced in this manual carefully and pay full attention to safety to handle the product correctly.
The precautions given in this manual are concerned with this product.
In this manual, the safety precautions are ranked as "DANGER" and "CAUTION".

⚠ DANGER Indicates that incorrect handling may cause hazardous conditions, resulting in death or severe injury.

⚠ CAUTION Indicates that incorrect handling may cause hazardous conditions, resulting in medium or slight personal injury or physical damage.

Note that the ⚠ CAUTION level may lead to a serious accident according to the circumstances.
Always follow the precautions of both levels because they are important to personal safety.
Please save this manual to make it accessible when required and always forward it to the end user.

[BACKLIGHT REPLACEMENT PRECAUTIONS]

⚠ DANGER

- Make sure to externally shut off all phases of GOT power supply (when GOT is connected via the bus type connection, make sure to shut off all phases of PLC CPU power supply as well) and remove the GOT from the control panel before backlight replacement.
  If all phases are not shut off, it may cause an electric shock.
  If backlight is replaced with the GOT on the control panel, the GOT may drop off, resulting in injuries.

⚠ CAUTION

- Make sure to wear gloves during backlight replacement.
  Failure to do so may cause injuries.
- Make sure to start the backlight replacement 5 or more minutes after power off of the GOT.
  Failure to do so may cause burn injuries as the old backlight holds heat for a while.

[STARTUP AND MAINTENANCE PRECAUTIONS]

⚠ CAUTION

- Before handling the GOT, make sure to touch a grounded metal object to discharge the static electricity from the human body.
  Failure to do so may cause the GOT to fail or malfunction.

[DISPOSAL PRECAUTIONS]

⚠ CAUTION

- Dispose of this product as industrial waste.

[TRANSPORTATION PRECAUTIONS]

⚠ CAUTION

- Make sure to transport the GOT main unit and/or relevant unit(s) in the manner they will not be exposed to the impact exceeding the impact resistance described in the general specifications of the GT16 User's Manual, as they are precision devices.
  Failure to do so may cause the unit to fail.
  Check if the unit operates correctly after transportation.

Manuals

The following shows manuals relevant to this product.

Detailed Manual

Manual name	Manual number (Model code)
GT12 Supplementary Description (Sold separately)	SH-080864ENG (1D7MB7)

Relevant Manuals

For relevant manuals, refer to the PDF manuals stored in the CD-ROM for the drawing software used.

© 2009 MITSUBISHI ELECTRIC CORPORATION

Packing List

After unpacking the box, check that the following products are included.

Model	Product	Quantity
GT12-70VLTN	Backlight	1
GT12-60VLTN		

1. OVERVIEW

This User's Manual describes GT12 backlight for 10.4"/8.4" GOT (hereinafter referred to as the backlight).
For applicable GOTs, refer to the following.

Product	Model	Description	GOT
Backlight	GT12-70VLTN	For 10.4" TFT (VGA)	GT1275-VNBA
	GT12-60VLTN	For 8.4" TFT (VGA)	GT1265-VNBA

2. SPECIFICATIONS

The following shows the performance specifications of the backlight.
The general specifications of the backlight are the same as those of the GOT.
For the general specifications of the GOT, refer to GT12 Supplementary Description.

Item	Specifications	
	GT12-70VLTN	GT12-60VLTN
Type	Cold cathode tube backlight	
Life	Approx. 50,000 h or longer(Time when display luminance reaches 50% at the operating ambient temperature of 25℃)	Approx. 40,000 h or longer(Time when display luminance reaches 50% at the operating ambient temperature of 25℃)
Weight	0.013kg (0.029lb)	0.006kg (0.013lb)

3. BACKLIGHT REPLACEMENT

The GOT includes the backlight for the liquid crystal display panel.
The backlight intensity decreases with time.
Replace the backlight when the display section becomes dark due to the decreased intensity and the picture is unclear.
The following shows the procedures for replacing the backlight.

1) Turn off the GOT.
2) Disconnect the power supply cable and the communication cable. Remove the GOT from the control panel.
3) Remove seven fixing screws on the GOT rear face with a screwdriver.



4) Open the battery cover and remove the case with passing the battery through the hole of the case. (Only when a battery is mounted.)
   When removing the case, take care not to detach the battery cable from the board.
   (Expanded figure of part A in 3))







5) Remove the cable connector of the backlight from the connector of the GOT board.
   (Expanded figure of part B in 3) with the case removed)



When replacing the GT16-70SLTT/70VLTT, remove the cables from the cable holder.



6) Press the backlight fixing latch (black) with your fingers, and pull out the backlight to the left.
When pulling out the backlight, press the packing with your fingers so that the backlight does not hit the packing.



(When replacing GT12-70VLTN)



(When replacing GT12-60VLTN)



7) Install a new backlight in the reverse procedure of removal.
When inserting a new backlight into the backlight replacement hole of the GOT, make sure not to damage the sheaths of the cables.
Insert the backlight until it is fixed by the latch (black).



Attach the thin cable, and then attach the thick cable to the cable holder as shown below. Install the cables so that the cables pass through in front of the supporter.
Assemble the case in the reverse procedure of disassembly.
(Tighten the fixing screws on the GOT rear face with a torque of 0.36 to 0.48 N•m).
When installing the case, make sure that the cables are not stuck between the case and the GOT.



Warranty

Mitsubishi will not be held liable for damage caused by factors found not to be the cause of Mitsubishi; machine damage or lost profits caused by faults in the Mitsubishi products; damage, secondary damage, accident compensation caused by special factors unpredictable by Mitsubishi; damages to products other than Mitsubishi products; and to other duties.

⚠For safe use

- This product has been manufactured as a general-purpose part for general industries, and has not been designed or manufactured to be incorporated in a device or system used in purposes related to human life.
- Before using the product for special purposes such as nuclear power, electric power, aerospace, medicine or passenger movement vehicles, consult with Mitsubishi.
- This product has been manufactured under strict quality control. However, when installing the product where major accidents or losses could occur if the product fails, install appropriate backup or failsafe functions in the system.

Country/Region	Sales office/Tel
U.S.A	Mitsubishi Electric Automation Inc. 500 Corporate Woods Parkway Vernon Hills, IL 60061, U.S.A. Tel : +1-847-478-2100
Brazil	MELCO-TEC Rep. Com.e Assessoria Tecnica Ltda. Rua Correia Dias, 184, Edificio Paraiso Trade Center-8 andar Paraiso, Sao Paulo, SP Brazil Tel : +55-11-5908-8331
Germany	Mitsubishi Electric Europe B.V. German Branch Gothaer Strasse 8 D-40880 Ratingen, GERMANY Tel : +49-2102-486-0
U.K	Mitsubishi Electric Europe B.V. UK Branch Travellers Lane, Hatfield, Hertfordshire., AL10 8XB, U.K. Tel : +44-1707-276100
Italy	Mitsubishi Electric Europe B.V. Italian Branch Centro Dir. Colleoni, Pal. Perseo-Ingr.2 Via Paracelso 12, I-20041 Agrate Brianza., Milano, Italy Tel : +39-039-60531
Spain	Mitsubishi Electric Europe B.V. Spanish Branch Carretera de Rubi 76-80, E-08190 Sant Cugat del Valles, Barcelona, Spain Tel : +34-93-565-3131
France	Mitsubishi Electric Europe B.V. French Branch 25, Boulevard des Bouvets, F-92741 Nanterre Cedex, France TEL: +33-1-5568-5568
South Africa	Circuit Breaker Industries Ltd. Private Bag 2016, ZA-1600 Isando, South Africa Tel : +27-11-928-2000
Hong Kong	Mitsubishi Electric Automation (Hong Kong) Ltd. 10th Floor, Manulife Tower, 169 Electric Road, North Point, Hong Kong Tel : +852-2887-8870
China	Mitsubishi Electric Automation (Shanghai) Ltd. 4/F Zhi Fu Plazz, No.80 Xin Chang Road, Shanghai 200003, China Tel : +86-21-6120-0808
Taiwan	Setsuyo Enterprise Co., Ltd. 6F No.105 Wu-Kung 3rd.Rd, Wu-Ku Hsiang, Taipei Hsine, Taiwan Tel : +886-2-2299-2499
Korea	Mitsubishi Electric Automation Korea Co., Ltd. 1480-6, Gayang-dong, Gangseo-ku Seoul 157-200, Korea Tel : +82-2-3660-9552
Singapore	Mitsubishi Electric Asia Pte, Ltd. 307 Alexandra Road #05-01/02, Mitsubishi Electric Building, Singapore 159943 Tel : +65-6470-2460
Thailand	Mitsubishi Electric Automation (Thailand) Co., Ltd. Bang-Chan Industrial Estate No.111 Moo 4, Serithai Rd, T.Kannayao, A.Kannayao, Bangkok 10230 Thailand Tel : +66-2-517-1326
Indonesia	P.T. Autoteknindo Sumber Makmur Muara Karang Selatan, Block A/Utara No.1 Kav. No.11 Kawasan Industri Pergudangan Jakarta - Utara 14440, P.O.Box 5045 Jakarta, 11050 Indonesia Tel : +62-21-6630833
India	Messung Systems Pvt, Ltd. Electronic Sadan NO:III Unit No15, M.I.D.C Bhosari, Pune-411026, India Tel : +91-20-2712-3130
Australia	Mitsubishi Electric Australia Pty. Ltd. 348 Victoria Road, Rydalmere, N.S.W 2116, Australia Tel : +61-2-9684-7777

MITSUBISHI ELECTRIC CORPORATION
HEAD OFFICE : TOKYO BUILDING, 2-7-3 MARUNOUCHI, CHIYODA-KU, TOKYO 100-8310, JAPAN
NAGOYA WORKS : 1-14, YADA-MINAMI 5-CHOME, HIGASHI-KU, NAGOYA, JAPAN

When exported from Japan, this manual does not require application to the Ministry of Economy, Trade and Industry for service transaction permission.

Specifications subject to change without notice.
Printed in Japan.